



OFFICE OF THE DEPUTY FIRE OFFICER,
BERHAMPUR CIRCLE, BERHAMPUR

Email :- dfobpr-ofs@gov.in (☎ 0680-2220050)

FORM-V

FIRE SAFETY CERTIFICATE

(See rule-13 (3) of the Odisha Fire Prevention and Fire Safety Rules, 2017)

File No. 47/2020

Certificate No. 34/2020 Dtd. 24.10.2020

This Certificate is valid up to 23.10.2022

(Apply for renewal at least three months before expiry)


Certified that the G+1 storied building of Army Public School, Gopalpur, Inside Gopalpur Military Station, Golabandha (Educational), situated at Mouza-Golabandha, Tahasil-Rangellunda (Kanis), Dist-Ganjam, Odisha, consisting of total 01 (One) building was inspected by Officers of Odisha Fire Service on 08.10.2020 & 24.10.2020 in presence of authorized representative of the school and it has been found to comply with the fire prevention and safety requirements in accordance with the Odisha Fire Prevention & Fire Safety Rules, 2017 read with the Odisha Fire Prevention & Fire Safety (Amendment) Rules, 2019 and Home Department Notification No. 28550/CD, Bhubaneswar Dtd. 28.08.2020 (One time relaxation scheme of Odisha Fire Service). Hence, its various floors are fit from fire safety point of view for occupancy or usage as noted hereunder against each, subject to compliance to the conditions as prescribed herein below :-

1.	G+1 storied building (Educational)	Usage	Army Public School
----	---------------------------------------	-------	--------------------

Conditions :-

1. Fire Prevention and safety measures and appliances, availability of water supplies and means of access thereto etc. provided in the building or premises, should be maintained by the occupier (s) in best repairs and efficient working condition at all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
2. The setbacks, driveways, entrance gates, exits, staircases, corridors and escape ways should not be changed, obstructed or modified in any way.
3. The occupier (s) shall train all staff and occupants periodically to make them well conversant in use and operation of the fire prevention and safety measures.
4. Fire Drills/rehearsals should be organized at least once in six months by involving local Fire Station.
5. Photocopies of this certificate should be framed and displayed at all conspicuous places in all lobbies/corridors in all towers/blocks of building/premises.

By order of the Director of Fire Service


24/10/2020
Deputy Fire Officer,

Berhampur Circle, Berhampur.

Name & Designation of the issuing Officer :- Debendra Kumar Swain, Deputy Fire Officer

ATTESTED


Pradeep Kumar
Principal APS, Gopalpur
Dist-Ganjam, Odisha-761052